



November 9, 2017

Via Website Posting and Email/Fax

Dear Sir/Madam:

Re: CL2017-43, MAC 2nd Floor Interior Alterations

Addendum Number 3

Bidders are hereby advised of Addendum Number **3** to the above noted Tender.

This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of the Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification.

A. Question and Answer

- 1. Question:** The revised schedule of finishes has all the carpet types listed as CPT1, whereas the finish plan is asking for CPT1, CPT2, CPT3. Can we get clarification of what colours are expected where?

Answer: Only one carpet type CPT1 to be installed throughout the space as per Addenda#1 Schedule of Finishes.

- 2. Question:** Also, is the alternate price to be all one colour, or multiple colours. If multiple, what is going where? As well, i'm assuming the Terazzo is to remain in the alternate price, and we install over with carpet tile. If so, is there a need to slope the floor, as noted on plan A104B?

Answer: The alternate price is for one colour CPT1 as specified. Carpet tile to be installed on top of the existing terazzo in which case the slope will not be necessary. It will require the existing carpeted areas to be leveled to the existing terazzo finish.

- 3. Question:** Contact information for the base building fire alarm contractor / manufacturer?

Answer: Focus Fire, Phone: 905-426-6000

CL2017-43 MAC 2nd Floor Interior Alterations

All submissions must be in accordance with this addendum and the addendum is to be signed in the space provided and returned as part of your submission.

If you require this information in an alternative format, please contact the Accessibility Coordinator at 905-623-3379 ext. 2131.

Yours truly,



Becky Rogers
Buyer
Purchasing Services

I/we hereby acknowledge receipt of this addendum.

Signed (Must be Signing Officer of Firm)

Position

Name of Firm